

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
 DIVISION OF PUBLIC WATER SUPPLIES
 FACILITY # IL1310300

FOR THE MONTH OF:

CHLORINATION

August 2024

Date	Time Meter Read	PUMP METER	Hours	Meter Reading (1000 gal)	Water Treated (1000 gal)	PRE-CHLORINATION CHLORINE DOSAGE		FINISHED WATER CHLORINE TESTS (mg/l)		
						Reading	Gallons	Address	FINISHED CHLORINE RESIDUAL DISTRIBUTION TOTAL	CHLORINE RESIDUAL DIST FREE
1	11:30		0	71428257	37,382	20	5	201 Necomer		
2	9:00		0	71451820	23,563	15	5			
3			0	71451820	0	15	0			
4	8:30		0	71500147	48,327	5.45	10	202 Necomer	2.20	
5			0	71500147	0	45	5			
6	7:30		0	71553042	52,895	35	10	201 Necomer	1.80	
7			0	71553042	0	35	0			
8	9:00		0	71605427	52,385	25	10			
9	9:45		0	71629988	24,561	20	5			
10	11:00		0	71656330	26,342	14	6	705 S Main	1.80	
11	8:00		0	71677169	20,839	9.45	5			
12	11:40		0	71708841	31,672	39	6	201 Necomer	3.00	2.50
13	7:00		0	71728071	19,230	34	5			
14	9:00		0	71752741	24,670	27	7			
15			0	71752741	0	27	0			
16	9:00		0	71775045	22,304	22	5	201 Necomer	2.00	
17	10:00		0	71783419	8,374	20	2			
18	9:00		0	71791853	8,434	18	2			
19	10:30		0	71802973	11,120	15	3	705 S Main	2.20	
20	9:30		0	71812081	9,108	9.45	6			
21			0	71812081	0	45	0			
22	9:30		0	71832112	20,031	33	12			
23	9:30		0	71841301	9,189	25	8	705 S Main	1.80	
24	8:30		0	71849325	8,024	20	5			
25	8:45		0	71860909	11,584	12	8	201 Necomer	1.80	
26	9:15		0	71874658	13,749	5.45	7			
27	8:30		0	71885290	10,632	40	5			
28	10:00		0	71896511	11,221	35	5	201 Necomer	2.00	
29	10:00		0	71905107	8,596	32	3			
30	10:30		0	71914666	9,559	25	7	705 S Main	2.20	
31	9:00		0	71922217	7,551	19	6			
Total			0		531,342		164			
Ave.					17,140					
Max.					31,672					
Min.					7,551					

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552

CERT. OR REG. NO.

*INDICATE TYPE OF CI RESIDUAL
 F=FREE; C=COMBINED; T=TOTAL

MIETER LOCATION: PUMP HOUSE

TYPE OF CI TEST KIT AND/OR METHOD USED:
 DR 300

DATE MONTHLY BACTERIOLOGICAL SAMPLES
 SUBMITTED:

**RECORD METER READING FROM LAST DAY
 OF PREVIOUS MONTH: