

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
FACILITY #:IL1310300

FOR THE MONTH OF:

August 2021
CHLORINATION

VILLAGE OF NORTH HENDERSON

Date	Time Meter Read	Meter Reading (1000 gal)	Water Treated (100 gal)	PRE-CHLORINATION CHLORINE DOSAGE		FINISHED WATER CHLORINE TESTS (mg/l)	DAY TANK	*
				Reading	Distribution Address			
**		42566946						
1	8:30	42590767	23.821				11.0	T
2	8:00	42615798	25.031	705 S Main		2.5	5.45	T
3		42615798	0			2.5	4.0	T
4	8:00	42671408	55.610	201 Newcomer		2.5	3.0	T
5	8:45	42696288	24.880				28.45	T
6	7:00	42719019	22.731				4.0	T
7	11:25	42747626	28.607	201 Newcomer		2.5	3.5	T
8	8:30	42769094	21.468	705 S Main		2.5	3.0	T
9	15:30	42802030	32.936	705 S Main		2.5	2.2	T
10	18:40	42830842	28.812				1.6	T
11	17:00	42853227	22.385				1.8	T
12	15:40	42876104	22.877	300 Short		2.5	5.45	T
13	16:15	42903094	26.990	201 Newcomer		2.5	4.1	T
14	11:30	42925066	21.972	201 Newcomer		2.5	3.6	T
15	17:00	42957177	32.111				3.0	T
16	15:30	42981872	24.695				2.5	T
17	18:50	43010872	29.000	201 Newcomer		2.5	1.2	T
18	8:30	43049250	38.378	705 S Main		2.5	1.2	T
19	8:00	43074232	24.982				9.45	T
20		43074232	0				3.9	T
21	9:00	43126549	52.317				2.9	T
22	7:30	43152799	26.250				2.5	T
23	7:30	43179726	26.927	300 short		3.0	1.5	T
24	8:00	43206349	26.623	201 Newcomer		3.0	1.5	T
25	8:00	43231859	25.510				8.45	T
26		43231859	0					T
27	9:00	43285227	53.368	705 S Main		3.0	1.2	T
28		43285227	0				3.3	T
29		43285227	0					T
30	8:30	43340463	55.236	201 Newcomer		3.0	2.3	T
31	9:30	43367340	26.877	201 Newcomer		3.0	1.2	T
Total			800.394				154.0	
Ave.			25.819					
Max.			38.378					
Min.			21.468					

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552

CERT. OR REG. NO.

*INDICATE TYPE OF CI RESIDUAL
F=FREE; C=COMBINED; T=TOTAL

Cert.

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED:

METER LOCATION: PUMP HOUSE
TYPE OF CI TEST KIT AND/OR METHOD USED:
COLOR DISC

**RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH: