

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
FACILITY #: IL1310300

VILLAGE OF NORTH HENDERSON
FOR THE MONTH OF: August 2023
CHLORINATION

Date **	Time Meter Read	Meter Reading (1000 gal)	Water Treated (100 gal)	PRE-CHLORINATION		FINISHED WATER			*
				Reading	Distribution Address	CI FINISHED	CHLORINE RESIDUAL DISTRIBUTION	DAY TANK	
1	8:30	61650469	39,745		201 necomer	3.0	1.0	23.0	T
2	8:00	61690214	40,660		705 S Main	3.0	1.1	15	T
3		61730874	0					6:40	T
4		61730874	0						T
5	20:00	61834447	103,573					10:45	T
6	10:00	61849580	15,133		201 necomer	3.0	1.4	40	T
7	9:00	61877381	27,801					32	T
8	7:45	61903084	25,703					25	T
9	9:20	61932352	29,268					15	T
10	9:15	61958971	26,619		201 necomer	3.0	1.0	7:40	T
11		61958971	0						T
12	7:00	62011592	52,621					24	T
13	11:00	62045178	33,586					14:45	T
14	8:45	62071713	26,535		201 Newcomer	3.0	1.0	39	T
15	9:15	62100473	28,760					30	T
16		62100473	0						T
17	10:15	62159198	58,725					12:40	T
18		62159198	0						T
19		62159198	0						T
20	9:40	62248745	89,547		201 necomer	3.0	1.0	16	T
21	8:30	62281901	33,156					8:40	T
22	8:45	62311315	29,414		201 necomer	3.0	1.0	31	T
23	14:15	62346148	34,833					20	T
24	8:00	62368549	22,401		201 Newcomer	3.0	1.0	15	T
25	8:00	62397006	28,457		705 S Main	3.0	2.5	1:40	T
26	9:00	62425505	28,499		705 S Main	3.0	1.0	30	T
27		62425505	0						T
28	9:00	62486170	60,665		201 necomer	3.0	1.0	14	T
29	8:00	62512877	26,707		201 necomer	3.0	1.0	5:40	T
30		62512877	0						T
31	8:00	62571112	58,235		201 Newcomer	3.0	1.0	24	T
Total			920,643					227.0	
Ave.			29,698						
Max.			34,833						
Min.			15,133						

I certify that the information in this report is complete and accurate to the best of my knowledge:

METER LOCATION: PUMP HOUSE

TYPE OF CI TEST KIT AND/OR METHOD USED:
COLOR DISC

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED: Cert.

**RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH:

REPORTED BY (SIGNATURE):

8552

CERT. OR REG. NO.

*INDICATE TYPE OF CI RESIDUAL
F=FREE; C=COMBINED; T=TOTAL