

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
DIVISION OF PUBLIC WATER SUPPLIES  
FACILITY #:IL1310300

VILLAGE OF NORTH HENDERSON  
FOR THE MONTH OF: December 2021  
CHLORINATION

Date	Time Meter Read	Meter Reading (1000 gal)	Water Treated (100 gal)	PRE-CHLORINATION CHLORINE DOSAGE		FINISHED WATER CHLORINE TESTS (mg/l)		DAY TANK	*
				Reading	Distribution Address	CI FINISHED	CHLORINE RESIDUAL DISTRIBUTION		
**		45190834						45.0	T
1	9:15	45206475	15,641					39	T
2	8:45	45221743	15,268		705 S Main	2.5		32	T
3	8:00	45236731	14,988					26	T
4		45236731	0		201 Newcomer	2.5		1.0	T
5	9:15	45269564	32,833					14	T
6	7:30	45286061	16,497					8:45	T
7	8:30	45303683	17,622		201 Newcomer	2.5		39	T
8	8:30	45322020	18,337					31	T
9	8:30	45337952	15,932		705 S Main	2.5		25	T
10	8:30	45353971	16,019					20	T
11	8:00	45366997	15,726		300 Short	2.5		13	T
12	9:00	45386409	16,712					6:45	T
13	9:00	45404564	18,155					40	T
14	7:30	45420499	15,935		201 Newcomer	2.5		34	T
15		45420499	0					20	T
16	8:30	45452235	31,736					14	T
17	9:00	45469675	17,440		403 oliver	2.5		1.0	T
18		45469675	0		705 S Main	2.5		1.0	T
19	8:00	45501918	32,243					2:35	T
20	8:30	45521729	19,811		403 oliver	2.5		27	T
21	8:30	45537812	16,083					20	T
22	9:15	45554737	16,925					14	T
23	8:14	45570200	15,463		403 oliver	3.0		8:35	T
24	8:45	45586525	16,325		403 oliver	3.0		27	T
25	8:15	45603574	17,049					21	T
26	8:30	45621006	17,432					15	T
27	9:00	45639034	18,028		705 S Main	3.0		9:45	T
28	8:00	45655836	16,802					38	T
29	8:45	45678140	22,304					31	T
30	8:30	45695522	17,382		403 oliver	3.0		25	T
31	9:00	45713080	17,558		403 oliver	3.0		18	T
Total			522,246					199.0	
Ave.			16,846						
Max.			22,304						
Min.			14,988						

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552

CERT. OR REG. NO.

\*INDICATE TYPE OF CI RESIDUAL  
F=FREE, C=COMBINED, T=TOTAL

METER LOCATION: PUMP HOUSE

TYPE OF CI TEST KIT AND/OR METHOD USED:  
COLOR DISC

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED:

Cert. 0

\*\*RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH: