

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
 DIVISION OF PUBLIC WATER SUPPLIES
 FACILITY #: IL1310300

VILLAGE OF NORTH HENDERSON
 FOR THE MONTH OF: February 2021
 CHLORINATION

Date	Time Meter Read	Meter Reading (1000 gal)	Water Treated (100 gal)	PRE-CHLORINATION CHLORINE DOSAGE		CI FINISHED	FINISHED WATER CHLORINE TESTS (mg/l)		DAY TANK	*
				Reading	Amount Used lbs		Calcu mg/l	CHLORINE RESIDUAL DISTRIBUTION		
**		38978757								
1	9:00	38996353	17,596			1.8	1.0	20.0	T	
2	7:20	39008767	12,414			1.8	1.0	13	T	
3	8:00	39023110	14,343			1.8	1.0	7.45	T	
4		39023110	0			1.8	1.0	39	T	
5	9:00	39051005	27,895			1.8	1.0	26	T	
6	9:15	39065319	14,314			1.8	1.0	20	T	
7	8:30	39080111	14,792			1.8	1.6	15	T	
8	13:00	39100307	20,196			2.0	1.6	7.45	T	
9	6:15	39109973	9,666			2.0	1.6	40	T	
10	8:30	39125975	16,002			2.0	1.6	35	T	
11	9:15	39140945	14,970			2.0	1.6	29	T	
12	10:40	39154015	13,070			2.0	1.6	22	T	
13	13:00	39170252	16,237			2.0	1.6	15	T	
14	7:45	39188001	17,749			2.0	1.6	11	T	
15	7:30	39213997	14,613			2.0	1.6	8.45	T	
16	9:30	39230583	16,586			2.0	1.6	41	T	
17	13:00	39246522	15,939			2.0	1.6	37	T	
18	9:00	39259090	12,568			2.0	1.6	30	T	
19	10:00	39273038	13,948			2.0	1.6	24	T	
20	8:30	39285377	12,339			2.0	1.6	18	T	
21	9:00	39301213	15,836			2.0	1.6	15	T	
22	6:00	39312667	11,454			2.0	1.6	10	T	
23	8:00	39326319	13,652			2.0	1.6	5.45	T	
24	7:00	39338450	12,131			3.0	2.8	40	T	
25	9:15	39353269	14,819			3.0	2.8	35.45	T	
26	10:00	39366226	12,957			2.5	2.0	38	T	
27	12:45	39382043	15,817			2.5	2.0	32	T	
28		39382043	0					25	T	
29		39382043	0					158	T	
30		39382043								
31		39382043								
Total			403,286							
Ave.			14,403							
Max.			20,196							
Min.			9,666							

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552
 CERT. OR REG. NO.

*INDICATE TYPE OF CI RESIDUAL
 F=FREE, C=COMBINED, T=TOTAL

Cert

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED:

**RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH:

METER LOCATION: PUMP HOUSE
 TYPE OF CI TEST KIT AND/OR METHOD USED:
 COLOR DISC