

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
 DIVISION OF PUBLIC WATER SUPPLIES
 FACILITY #: IL1310300

VILLAGE OF NORTH HENDERSON
 FOR THE MONTH OF: March 2023
 CHLORINATION

Date	Time Meter Read	Meter Reading (1000 gal)	Water Treated (100 gal)	PRE-CHLORINATION CHLORINE DOSAGE		CI FINISHED	FINISHED WATER CHLORINE TESTS (mg/l)		*
				Reading	Distribution Address		CHLORINE RESIDUAL DISTRIBUTION	DAY TANK	
**		57402004	18,876					40.0	T
1	9:00	57420880	18,386	705 S Main		3.0	1.0	31	T
2	8:30	57439266	18,555	705 S Main		3.0	1.8	23	T
3	9:00	57457821	18,025	403 Oliver		3.0	1.2	15	T
4	8:30	57475846	0					7.40	T
5		57475846	0					22	T
6	8:30	57517056	41,210					14	T
7	9:15	57536312	19,256	705 S Main		3.0	1.6	6:40	T
8	8:00	57553920	17,608					24	T
9		57553920	0					24	T
10	8:00	57591538	37,618					15	T
11	8:30	57610187	18,649	705 S Main		3.0	3.0	8:40	T
12	8:00	57628394	18,207	705 S Main		3.0	3.0	37	T
13	8:00	57649579	21,185	705 S Main		3.0	1.5	31	T
14	7:00	57668966	19,387					23	T
15	10:45	57688561	19,595					15	T
16	11:00	57707575	19,014	403 Oliver		3.0	1.5	8:40	T
17	9:00	57724956	17,381					33	T
18	11:00	57743186	18,230					24	T
19	8:00	57762659	19,473					16:45	T
20	9:00	57785195	22,536						T
21		57785195	0					31	T
22	8:30	57843841	58,646					24	T
23	8:50	57872590	28,749	403 Oliver		3.0	1.0	17	T
24	9:00	57891699	19,109	403 Oliver		3.0	3.0	10:45	T
25	7:30	57909240	17,541					29	T
26		57909240	0	705 S Main		3.0	1.2	10	T
27	8:45	57951304	42,064					13	T
28	8:15	57970533	19,229					5:40	T
29	7:00	57989690	16,309	403 Oliver		3.0	1.2	30	T
30	7:00	58005999	22,590	705 S Main		3.0	1.2	22:10	T
31	11:00	58028589	626,585						
Total			20,212						
Ave.			28,749						
Max.			16,309						
Min.									

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552
 CERT. OR REG. NO.

Cert. (SUBMITTED)

METER LOCATION: PUMP HOUSE
 TYPE OF CI TEST KIT AND/OR METHOD USED:
 COLOR DISC
 DATE MONTHLY BACTERIOLOGICAL SAMPLES
 SUBMITTED:

*INDICATE TYPE OF CI RESIDUAL
 F=FREE; C=COMBINED; T=TOTAL

**RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH: