

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES  
 FACILITY # IL 1310300

FOR THE MONTH OF: \_\_\_\_\_

CHLORINATION

October 2024

Date	Time Meter Read	PUMP METER	Hours	Meter Reading (1000 gal)	Water Treated (1000 gal)	PRE-CHLORINATION CHLORINE DOSAGE			FINISHED WATER CHLORINE TESTS (mg/l)	
						Reading	Gallons	Address	CHLORINE RESIDUAL DISTRIBUTION TOTAL	CHLORINE RESIDUAL DIST FREE
**				72238799		31				
1	6:30		0	72246991	8,192	28	3	705 S Main	1.65	
2	10:00		0	72259159	12,168	24	4			
3			0	72283673	0	24	0	705 S Main	1.50	
4	16:00		0	72283673	24,514	14	10			
5			0	72283673	0	14	0			
6	11:30		0	72306166	22,493	6,45	8		1.33	
7	16:00		0	72323172	17,006	39	6			
8	15:50		0	72336626	13,454	34	5			
9	9:30		0	72350129	13,503	28	6			
10	7:00		0	72364149	14,020	21	7			
11			0	72364149	0	21	0	705 S Main	1.49	
12	10:00		0	72386412	22,263	11	10			
13	8:30		0	72399972	13,560	6,45	5			
14	9:45		0	72414324	14,352	40	5			
15			0	72414324	0	40	0			
16	10:30		0	72439200	24,876	30	10			
17			0	72439200	0	30	0	201 Necomer	1.20	
18	8:30		0	72461983	22,783	20	10			
19	9:30		0	72474157	12,174	15	5			
20	14:30		0	72494296	20,139	8,45	7			
21			0	72494296	0	8,45	0	201 Necomer	1.75	
22	14:30		0	72520222	25,926	35	10			
23	14:00		0	72531642	11,420	30	5			
24	12:00		0	72542805	11,163	25	5			
25	9:20		0	72554293	11,488	20:30	5	705 S Main	2.09	
26	9:40		0	72567462	13,169	25	5			
27	14:50		0	72584708	17,246	19	6	705 S Main	1.11	
28			0	72584708	0	19	0			
29	9:00		0	72607663	22,955	10	9			
30	9:00		0	72621275	13,612	5,45	5			
31	10:00		0	72635030	13,755	40	5			
Total			0		396,231					
Ave.					12,781					
Max.					20,139					
Min.					8,192					

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE): \_\_\_\_\_

METER LOCATION: PUMP HOUSE

8552  
 CERT. OR REG. NO.

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED: \_\_\_\_\_  
 \*\*RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH:

\*INDICATE TYPE OF CI RESIDUAL  
 F=FREE; C=COMBINED; T=TOTAL