ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
FACILITY # IL1310300

VILLAGE OF NORTH HENDERSON
FOR THE MONTH OF: September 2026

CHLORINATION

Date	Time Meter Read	PUMP METER	Hours	Meter Reading (1000 gal)	Water Treated (1000 gal)	PRE-CHLORINATION CHLORINE DOSAGE Reading	Gallons	Address	FINISHED WATER CHLORINE TESTS (mg/l) CI FINISHED	CHLORINE RESIDUAL DISTRIBUTION TOTAL	CHLORINE RESIDUAL DIST FREE
**				84537465		26					
1*	9:15		0	84553328	15,863	24	2				
2	11:30		0	84572203	18,875	21	3				
3	9:00		0	84587089	14,886	20	1	705 S Main		1.29	1.11
4			0	84587089	0						
5	8:00		0	84622812	35,723	14	6				
6	10:00		0	84661264	38,452	9	5				
7*	7:30		0	84677773	16,509	5;45	4	705 S Main		1.50	
8			0	84677773	0						
9			0	84677773	0						
10			0	84677773	0						
11	7:00		0	84733494	55,721	35	10				
12			0	84733494	0						
13*	16:30		0	84765563	32,069	32	3	201 Necomer		1.39	0.59
14			0	84765563	0						
15	18:10		0	84799385	33,822	26	6	705 S Main		1.50	
16			0	84799385	0						
17	19:00		0	84832730	33,345	20	6	705 S Main		1.69	0.70
18			0	84832730	0						
19	11:00		0	84857380	24,650	15	5				
20			0	84857380	0						
21*	8:40		0	84886537	29,157	10	5	705 S Main		1.61	0.62
22	6:45		0	84899537	13,000	9;45	1				
23			0	84899537	0						
24	9:30		0	84928718	29,181	40	5				
25			0	84928718	0						
26	13:00		0	84959248	30,530	34	6	705 S Main		1.50	
27*	9:30		0	84972049	12,801	31	3				
28	6:15		0	84986577	14,528	29	2	705 S Main		1.35	1.18
29	9:00		0	85001855	15,278	27	2				
30			0	85001855	0						
31			0	85001855	0						
Total			**0**		**505,621**		**75**				
Ave.					**17,435**						
Max.					**38,452**						
Min.					**12,801**						

WELL 129.6 #1 0.1 #2 21.4 JOCKEY 619.3 GEN 1.0

I certify that the information in this report is complete and accurate to the best of my knowledge:

REPORTED BY (SIGNATURE):

8552
CERT. OR REG. NO.

*INDICATE TYPE OF CI RESIDUAL
F=FREE; C=COMBINED; T=TOTAL

METER LOCATION: PUMP HOUSE

TYPE OF CI TEST KIT AND/OR METHOD USED:
DR 300

DATE MONTHLY BACTERIOLOGICAL SAMPLES SUBMITTED:

**RECORD METER READING FROM LAST DAY OF PREVIOUS MONTH: